



SOUTH SAN LUIS OBISPO SD
R3-2004-0050

Monthly eSMR SUMMARY

Expected Requirements:

M-001:

Chlorine Usage	1 / Day	lb/day
Chlorine, Total Residual	1 / Day	mg/L
Fecal Coliform	5 / Week	MPN/100 mL
Total Coliform	2 / Week	MPN/100 mL
Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1 / Week	mg/L
Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1 / Week	lb/day
BOD5 @ 20 Deg. C, Percent Removal	1 / Week	%
Oil and Grease	1 / Week	mg/L
Oil and Grease	1 / Week	lb/day
pH	1 / Week	SU
Settleable Solids	1 / Week	ml/L
Temperature	1 / Week	Degrees C
Total Suspended Solids (TSS)	1 / Week	mg/L
Total Suspended Solids (TSS)	1 / Week	lb/day
Total Suspended Solids (TSS), Percent Removal	1 / Week	%
Turbidity	1 / Week	NTU

M-INF:

Flow	1 / Day	MGD
Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1 / Week	mg/L
Total Suspended Solids (TSS)	1 / Week	mg/L

Using Narratives Tab:

Fecal Coliform: The average weekly 7-sample median for fecal coliform may not exceed 200MPN/100ml. (Final requirement effective null - null)[All year]

Radioactivity: Not to exceed limits specified in Title 17, Division 1, Chapter 5, Subchapter 4, Group 3, Article 3, Section 30269 of the California Code of Regulations. (Final requirement effective null - null)[All year]

Using Pre-Calculated Tab:

N/A

Using Raw Data Tab:

N/A